

Our Ref: HL/M100419

3rd February 2010

Girpi,
Rue Robert Ancel,
BP36,
F76700,
Harfleur,
France

Dear Sir

WATER REGULATIONS ADVISORY SCHEME

"ITEMS WHICH HAVE PASSED FULL TESTS OF EFFECT ON WATER QUALITY - BS 6920"

We refer to your application for the material(s) described below to be approved arising from the results of the tests of effect on water quality that have been carried out on the product(s) so described, it has been decided that there is no objection to its/their use provided the source, nature and manufacturing processes of the ingredients and products are not changed. (See notes overleaf).

POLYVINYLCHLORIDE (LEAD FREE PVC, PVC-U AND CPVC) - COMPONENTS 5305

HTA extruded CPVC pipe (dark brown colour) for use with injection moulded HTA CPVC fittings (brown colour). For use with hot and cold water up to 70°C.

HTA-F CPVC pipe (orange colour) for use with injection moulded HTA CPVC fittings (brown colour). For use with cold water only.

The pipe may be joined to the fittings using Rerfix adhesive (orange colour).

Test Report: MAT/LAB 841A & 842A

0904539

GIRPI

An entry, as above, will accordingly be included in the Water Fittings Directory on-line, Part Two, under the section headed, "Materials which have passed full tests of effect on water quality".

Your attention is drawn to the statement overleaf. Manufacturers or applicants may only quote in their sales literature terms which are used in this letter, namely that the product as listed, having passed the tests of effect on water quality, is suitable for use in contact with potable water and that a reference to the product will be included in the Materials section, Part Two, of the Water Fittings Directory on-line: this may be abbreviated to "Water Regulations Advisory Scheme - Approved Material" or "WRAS - Approved Material". **Approval of this product does not signify the approval of its mechanical or physical properties for any use.**

The Technical Committee of the Scheme reserves the right to review approval. This product automatically becomes due for audit reassessment in April 2014.

Yours faithfully

H. E. Lewis

Hannah Lewis
WRAS Approvals Administrator
Water Regulations Advisory Scheme